


# **SAFETY CERTIFICATE**


The Building of Cambridge International School Near Kalu Di Hatti Teh. Palampur Distt. Kangra H.P was inspected by the Junior Engineer of Ghar Section on dated 15.05.2023. It has been observed that no earthquake resistant provisions have been adopted for this building and no structural drawings are approved by any competent Govt. certified Engineer/authority, have been produced at the time of inspection. More over no assistance was taken from PWD for constructing the building. Hence, the structural safety of this building cannot be ensured. This department will not be responsible for any type of loss of life and property etc., if this structure fail under any circumstances.


However, as per visual inspection the building has been found safe in appearance only. No Officer/Official of this office will attend plea in any Hon'ble court of Law in case of any dispute. This certificate is valid for the session 2023-24.

Place: - Palampur

Dated:- 15.05.2023

  
Assistant Engineer,  
Palampur Sub-Division,  
HP.PWD Palampur.

  
Executive Engineer,  
Palampur Division,  
HP.PWD Palampur.

  
Principal  
Cambridge International School  
Palampur, Kangra (H.P.)

  
Chairman  
Cambridge International School  
Palampur, Kangra (H.P.)